

The Control Hub requires a 230-240 VAC, 47 ~ 63Hz single phase supply. A 32Amp RCBO should be used for each Control Hub.

All electrical installation to be carried out by an approved electrician in accordance with Part "P" U.K. Building Regulations and to the latest IEEE standards, or the appropriate regulations in the country of installation.

